




इन्दौर सहकारी दुग्ध संघ मर्यादित

INDORE SAHAKARI DUGDH SANGH MYDT.

An ISO 9001 : 2015 : 2015, 22000:2005 & 14001 Certified Organisation

GSTIN - 23AAAJI0016N1ZK



शुद्धता का संकल्प

चांदा तलावली मांगलिया, इन्दौर - 453 771 (म.प्र.) Chanda Talawali, Manglia, INDORE - 453771 (M.P.)

दूरभाष / Phone : 0731-2802535, 2811553, 2811162, 2811132

फैक्स / Fax : 0731-2811559 ई-मेल/E-mail : sanchimsids@gmail.com

Toll Free No. 18002332535

No.: 3305 :ISDSM/GMPO/2024

Dated 17.01.2024

//AMENDMENT//

Following amendments have been done in E-Tender no 2024_MPCDF_324403_1 of Supply, Installation & Commissioning of Milk cold Room for 100 KL capacity in Main dairy plant Indore. Please read following technical specification.

Page No	Sr. No	Specification	Querries and suggestions by bidder	Final Amendment
6	5	A) Schedule -II, 2.1 Requirements for cold room	Floor = 80mm, Ceiling = 80mm, wall =80mm	As per tender
6	4	Compressor operating duty	-5°C EVA & 40 °C COND Temp.	-5°C EVA & 40 °C COND Temp.
6	1,2,3, 6,10	Schedule -II, 2.2 Major items proposed	Air curtains = 2 no, PVC strip 04 no Data logger duration = 15 days	Air curtains = 2 no PVC strip = As per tender Data logger duration = 15 days
7	7	C. Electrical details	Electrical panel shall be provided by bidder.	Electrical panel shall be provided by bidder.
8	II	D. Supply, installation & commissioning of ammonia based compressor, Evaporation unit	Back pressure valve for each evaporation unit =5 no(Make - Denfoss/Manik	Back pressure valve for each . evaporation unit =5 no (Make - Denfoss/Manik. All the ammonia line valve will be flange type.
				Existing pump of LPR system shall be used for supply of Ammonia refrigerant
3	4.0	Delivery period	90 days	As per tender

General Manager(PO)

